

Crystal Orr

From: ALTON Greg * DEQ <greg.alton@deq.state.or.us>
Sent: Thursday, July 8, 2021 3:11 PM
To: Crystal Orr
Cc: Jill Rolfe
Subject: RE: P-21-003 TRC MEMO

This Message originated outside your organization.

OK. My comments are if the house is on septic currently they need to show it on the Plat and specify its fate. Either to continue to service the existing residence or properly decommission the tank in place and submit appropriate documentation to DEQ.

Gregory H Alton
Regional Onsite Wastewater Specialist
381 N 2nd St
Coos Bay, OR 97420
541-269-2721 Ext. 225



From: Crystal Orr <corr@co.coos.or.us>
Sent: Thursday, July 8, 2021 2:45 PM
To: ALTON Greg * DEQ <greg.alton@deq.state.or.us>
Subject: RE: P-21-003 TRC MEMO

I don't think I will be doing this one via zoom unless you would like to be included? This was kind of a last minute meeting because staff will be on vacation.

Crystal Orr

Planner I
Coos County Planning
60 E Second St, Coquille, OR 97423 (Physical address)
225 N Adams St, Coquille, OR 97423 (Mailing Address)
541-396-7770

From: ALTON Greg * DEQ <greg.alton@deq.state.or.us>
Sent: Thursday, July 8, 2021 2:32 PM
To: Crystal Orr <corr@co.coos.or.us>
Subject: RE: P-21-003 TRC MEMO

This Message originated outside your organization.

Hi Crystal,
Are you going to send out a zoom invite? This one is on sewer so not much for me other than it appears the existing residence is likely on septic and there is a well that's not shown just the well house.
Thanks, Greg

Gregory H Alton